



RE: LHS - PCB Waste Profile

Glenn Nelson

to:

Kimberly Tisa

04/10/2012 10:10 PM

Cc:

Bill Wessel

Hide Details

From: Glenn Nelson <gnelson@smithwessel.com>

To: Kimberly Tisa/R1/USEPA/US@EPA

Cc: Bill Wessel <bwessel@smithwessel.com>

1 Attachment



image001.png

Hi Kim,

Yes, you are correct. The intent is to send the window caulk to Minerva as it is < 50 ppm and the >50 ppm and associated materials that are in contact shall be sent to Model City. I have a request into RM Tech regarding the hauler for materials going to Minerva and whether they notified as a PCB transporter.

Regards,
Glenn

From: Kimberly Tisa [<mailto:Tisa.Kimberly@epamail.epa.gov>]

Sent: Tuesday, April 10, 2012 8:07 PM

To: Glenn Nelson

Subject: FW: LHS - PCB Waste Profile

Glenn-

Can you please confirm with RM Tech how they are managing the PCB caulk around the windows?

In the PCB Abatement Plan, I believe you had indicated that **all** caulk would be disposed of as a PCB bulk product waste, which by definition is a PCB > 50 ppm.

I seem to recall that RM Tech indicated it was separating the < 50 ppm PCB caulk (and associated windows) from the > 50 ppm for purposes of disposal; that is, that the < 50 ppm caulk and windows would go to Minerva and the > 50 ppm PCB caulk (and any materials in contact with this caulk) would go to Model City.

This certainly would be allowed under 761.62(a) and (b), but I just need clarification and confirmation, because of what was indicated in the Work Plan which S&W provided.

Hopefully I'm remembering this correctly as I was on my way home and didn't have the latest versions of the Work Plan or the CWP with me.

With respect to Minerva, who is the transporter and did they notify as a PCB transporter?

Kimberly N. Tisa
U.S. Environmental Protection Agency
5 Post Office Square, Suite 100
Mail Code: OSRR07-2
Boston, MA 02109-3912

Phone: 617.918.1527
E-Fax: 617.918.0527

tisa.kimberly@epa.gov

-----Glenn Nelson <gnelson@smithwessel.com> wrote: -----

To: Kimberly Tisa/R1/USEPA/US@EPA
From: Glenn Nelson <gnelson@smithwessel.com>
Date: 04/10/2012 05:25PM
Cc: Bill Wessel <bwessel@smithwessel.com>
Subject: FW: LHS - PCB Waste Profile

Hi Kim,

See information as provided by RM Technologies below.

I left message on Molly's voice mail and hope to hear back from her.

Thanks,
Glenn

From: Alex Santos [<mailto:ASantos@rmtechnologies.com>]
Sent: Tuesday, April 10, 2012 4:52 PM
To: Glenn Nelson
Subject: FW: LHS - PCB Waste Profile

Hi Glen,

Waste Management will use either Goulet Trucking Inc (EPA ID # MAC30006038) or Tonawanda Tank Transport (EPA ID # NYD097644801) to transport the waste.

Please let me know if anything else is needed.

Thank you,

Alex Santos



R.M. TECHNOLOGIES, INC.

33 Franklin Street, 2nd floor

Lawrence, MA 01840

Tel.978-794-0006

Cell.978-423-9770

Fax.978-794-1057

